# :hager

## **Consumer Unit Design 10 Flush 100A Switch Disconnector**

For the distribution of power in a residential application, conforming to BS EN 61439-3 including Annex ZB (16kA rating).

Design 10 has been created as an entry level board which meets the requirements of the wiring regulations (BS 7671) and allows the consumer unit to be installed flush at the height stated in the building regulations (Part M), with minimum impact on the area.

Regulation 421.1.201 within domestics (household) applications consumer units and similar assemblies shall comply with BS EN 61439-3 and shall have their enclosure manufactured from a non-combustible material.

Regulation 411.3.3 additional protection by means of a 30mA RCD is provided by RCBOs.

Regulation 314.1&2 segregation of circuits to avoid danger and minimise inconvenience in the event of a fault.

Regulation 522.6.202 protection of wiring concealed in walls or partitions.


Regulation 531.3.3 Selection of appropriate RCD. Type A RCBOs can detect and respond to both AC and pulsating DC components.

Regulation 536.4.3.2 & 536.4.202 overload protection of switches and RCCBs. For installations where the upstream overcurrent protection is less than or equal to 100 A.

The flush design removes the harsh appearance of a surface mounted enclosure on the wall.







VMLF110

#### Description

Devices

Boonpain	Size	Cat Ref.
10 Way Flush 100A Switch Disconnector Incomer	4	VMLF110
14 Way Flush 100A Switch Disconnector Incomer	5	VMLF114
20 Way Flush 100A Switch Disconnector Incomer	7	VMLF120

Single Pole, Single Mod RCBO 6kA, 40A - 45A Type A	ADA1**G
Single Pole, Single Mod Reduced Height RCBO 6kA, 6A - 32A Type A	ADA3**G

## **Features & Benefits**

- Cable clamp Secures supply cables on entry to main incoming device preventing any movement being transmitted through meter tails to device
- Rear Knockouts for ease of cable entry Cable protector plate (VM02CE) provided
- 2 piece base allows for first fix, second fix option
- Adjustable Depth Base Base assembly is adjustable from 72mm to 92mm, at 72mm allows for 60mm studwork and 12mm plasterboard
- Full metal DIN rail Secure and stable attachment of devices
- Quick release clip on MCB/RCBO Allows removal of MCB/RCBO with busbar still in place
- Optimised cabling space DIN rail position allows maximum cabling space
- Top mounted terminal rail makes the wiring of the neutral and earth connections neat and simple.
- Torque settings displayed inside front cover so they're easily accessible by the electrician.

### **Technical Characteristics**

Standards	BS EN 61439-3
Classification	Consumer Unit
Rated & Operational Voltage (Un/Ue)	230V a.c 50 Hz
Rated Insulation Voltage (Uj)	320V a.c. 50Hz
Rated Frequency (fn)	50 Hz
Rated impulse withstand voltage (Uimp)	4kV
Rated Current of the Assembly (Ina)	100A
Rated Current of an Outgoing Circuit I <sub>n</sub> C	ADA1**G RCBO 40A - 45A (Marked Rated Current on Device) ADA3**G RCBO 6A - 32A (Marked Rated Current on Device)
Rated Conditional Short Circuit of the Assembly ( $I_{CC}$ )	Annex ZB: 16kA rms at 250V, power factor 0.6 with equipment and arrange- ments specified in Hager's technical documentation/catalogue
Protection against electric shock	Consumer Unit shall be installed in an electrical system conforming to IEC 60364 / BS 7671
Rated Diversity Factor (RDF) / Values of assumed loading	10 way and above - 0.5
Note: RDF only applies to continuously and simultaneously loaded circuits In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than
In principle, this means adjacent circuit breakers having a load on time exc	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than d.
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated Pollution Degree Types of System Earthing for which the assembly is designed	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than d.
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated Pollution Degree	2   TNC-S and TN-S when installed in an electrical system conforming to BS 7671
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated Pollution Degree Types of System Earthing for which the assembly is designed Intended locations	2   TNC-S and TN-S when installed in an electrical system conforming to BS 7671
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated Pollution Degree Types of System Earthing for which the assembly is designed Intended locations Stationary assembly Degree of protection	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than id.   2   TNC-S and TN-S when installed in an electrical system conforming to BS 7671   Indoor use only   IP2XC with door open / closed and full compliment of devices / blanks fitted. Note: Where cables are installed through the top wall of the enclosure, gaps of
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated Pollution Degree Types of System Earthing for which the assembly is designed Intended locations Stationary assembly Degree of protection Intended use	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than   d.   2   TNC-S and TN-S when installed in an electrical system conforming to BS 7671   Indoor use only   IP2XC with door open / closed and full compliment of devices / blanks fitted.   Note: Where cables are installed through the top wall of the enclosure, gaps of IP4X to be maintained.
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated Pollution Degree Types of System Earthing for which the assembly is designed Intended locations Stationary assembly Degree of protection Intended use Electromagnetic compatibility (EMC) classification	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than   id.   2   TNC-S and TN-S when installed in an electrical system conforming to BS 7671   Indoor use only   IP2XC with door open / closed and full compliment of devices / blanks fitted.   Note: Where cables are installed through the top wall of the enclosure, gaps of IP4X to be maintained.   Intended for use in domestic (residential) or similar premises
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated Pollution Degree Types of System Earthing for which the assembly is designed Intended locations Stationary assembly Degree of protection Intended use Electromagnetic compatibility (EMC) classification External design	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than id.   2   TNC-S and TN-S when installed in an electrical system conforming to BS 7671   Indoor use only   IP2XC with door open / closed and full compliment of devices / blanks fitted. Note: Where cables are installed through the top wall of the enclosure, gaps of IP4X to be maintained.   Intended for use in domestic (residential) or similar premises   EMC environment B
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated Pollution Degree Types of System Earthing for which the assembly is designed Intended locations Stationary assembly Degree of protection Intended use Electromagnetic compatibility (EMC) classification External design Mechanical impact protection	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than id.   2   TNC-S and TN-S when installed in an electrical system conforming to BS 7671   Indoor use only   IP2XC with door open / closed and full compliment of devices / blanks fitted. Note: Where cables are installed through the top wall of the enclosure, gaps of IP4X to be maintained.   Intended for use in domestic (residential) or similar premises   EMC environment B   Wall mounted, surface type, enclosed assembly.
In principle, this means adjacent circuit breakers having a load on time exc the 'on' time will need to have the rated diversity factor applied as indicated Pollution Degree Types of System Earthing for which the assembly is designed Intended locations Stationary assembly	ceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than   d.   2   TNC-S and TN-S when installed in an electrical system conforming to BS 7671   Indoor use only   IP2XC with door open / closed and full compliment of devices / blanks fitted.   Note: Where cables are installed through the top wall of the enclosure, gaps of IP4X to be maintained.   Intended for use in domestic (residential) or similar premises   EMC environment B   Wall mounted, surface type, enclosed assembly.   IK05

Warranty - Hager undertakes to replace or repair at its discretion products should they become inoperable within the time periods as stated - 2 Years.

### Accessories

38mm Open Grommet	Allows protection of cables entering top or bottom of the enclosure	VMGROM
Grommet strip	For protecting cables against damage when entering the board	VM05GS

### Flush Design 10 Dimensions (mm)

	Enclosure Size		
	4	5	7
Height	282	282	282
Width	335	407	515
C	32	32	32
D	298	370	478
E	252	252	252
F	72	72	72

		Number of Knockouts		
$\bigcirc$	Top Face 50 x 20 (mm)	4	5	7
	Bottom Face 50 x 20 (mm)	4	5	7
$\bigcirc$	Back 100 x 50 (mm)	2	2	3
$\bigcirc$	Left Face 20.8 (mm)	1	1	1

